

Certificate of Compliance

Certificate Number 051904-E169468
Report Reference E169468, May 19, 2004
Issue Date 2004 May 19

Page 1 of 1



Issued to: **Myers Power Products**
2950 E. Philadelphia St.
Ontario, CA 91761


This is to certify that representative samples of Metal Enclosed Low-Voltage Power Circuit Breaker Switchgear

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1558, Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear; ANSI/IEEE C37.20.1-1987, Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear; ANSI C37.51-1989, Metal-Enclosed Low-Voltage AC Power Circuit Breaker Switchgear Assemblies-Conformance Test Procedures.

Additional Information: Maximum rating as follows:
* 635 V ac
* 10,000 Amps
* 200 KA Short-Circuit Rating
* 85 KA Short-Time Rating

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:
Joyce A. Nguyen
Underwriters Laboratories Inc.

Reviewed by:
Ron Breschini
Underwriters Laboratories Inc.