

Certificate of Compliance

Certificate Number 051904-E152143
Report Reference E152143, May 19, 2004
Issue Date 2004 May 19

Page 1 of 1



Issued to: **Myers Power Products**
2950 E. Philadelphia St.
Ontario, CA 91761


This is to certify that representative samples of Metal-Clad Switchgear - Over 600 V ac

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/IEEC C37.20.2-1987, Metal-Clad and Station Cubicle Switchgear; ANSI C37.55-1989, Metal-Clad Switchgear Assemblies-Conformance Test Procedures

Additional Information: Maximum ratings as follows:
* 15 KV * 36 KV Low Frequency Withstand
* 3,000 Amps * 48 Short-Time Rating
* 95 KV Impulse Withstand

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:
Joyce A. Nguyen
Underwriters Laboratories Inc.

Reviewed by:
Ron Breschini
Underwriters Laboratories Inc.